



Ag Testing - Consulting

Account No. :

Water Analysis Report

Invoice No. :

Date Received : 02/22/2013

Date Reported : 02/25/2013

Lab Number : 928

Results For :

Location :

Sample ID :

pH	8.1
Total Dissolved Solids (TDS) Est, ppm	202
Electrical Conductivity, mmho/cm	0.34
Cations / Anions, me/L	3.4 / 3.5

**ppm**

Sodium, Na	4
Potassium, K	< 1
Calcium, Ca	35
Magnesium, Mg	18
Total Hardness, CaCO <sub>3</sub>	163
Nitrate, NO <sub>3</sub> -N	0.6 (SAFE)
Sulfate, SO <sub>4</sub> -S	2
Chloride, Cl	5
Carbonate, CO <sub>3</sub>	9
Bicarbonate, HCO <sub>3</sub>	179
Total Alkalinity, CaCO <sub>3</sub>	161
Total Phosphorus, P	0.50
Total Iron, Fe	0.01

"<" - Not Detected / Below Detection Limit

Reviewed By : Joshua Skrdla

2/26/2013

Copy : 1

Page 1 of 1

Bus: 308-234-2418  
Fax: 308-234-1940

web site  
www.wardlab.com

4007 Cherry Ave., P.O. Box 788  
Kearney, Nebraska 68848-0788